

Units 9+10



E & D Water Wells, LLC

3530 West Space Ln.
Wasilla, AK 99623
(907) 373-1598 Fax: (907) 357-1598



Borough	Subdivision	Lot	Block	Section QTRS.	Section	Township	Range	Meridian
MAT-SU	CASIS AT Birch Lake	5	1					Seward
Location / Sketch				Well Owner <u>to PAUL</u> <u>STAPLEY CONSTRUCTION</u> <u>841-1724</u>				
Depth Measured From: <input checked="" type="checkbox"/> Casing Top <input type="checkbox"/> Ground Surface				Well Depth:		Date Of Completion		
Borehole Data: Material Type & Color				Depth From To		Depth of Hole: <u>81</u> Ft. Depth of Casing: <u>80</u> Ft.		<u>4/23/16</u>
Stick up		0	3	Depth To Static Water Level: <u>20</u> Ft. Below <input checked="" type="checkbox"/> Top of Casing <input type="checkbox"/> Ground Surface				
Soil - mixed		3	5	Date: <u>4/23/16</u>				
SANDY GRAVEL		5	19	Method Of Drilling: <input checked="" type="checkbox"/> Air Rotary <input type="checkbox"/> Cable Tool <input type="checkbox"/> Other: _____				
WATER ^{FROM} SANDY GRAVEL		19	47	Use Of Well: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Monitor <input type="checkbox"/> Public Supply <input type="checkbox"/> Other				
WET SILTY CLAY		47	65	Casing Stick-Up: <u>3</u> Ft. Diam: <u>6</u> In. to _____ Ft. Casing Type: <u>A53B STEEL</u> 20 In. to _____ Ft.				
WATER GRAVEL		65	81	Well Intake Opening Type: <input checked="" type="checkbox"/> Open End <input type="checkbox"/> Screened <input type="checkbox"/> Perforated <input type="checkbox"/> Open Hole				
Iron Free Test 3/4/17				Depths Of Openings: <u>80</u> To: <u>81</u> Ft.				
Iron		3		Screen Type: <u>none</u> Diameter: _____ In. _____ Slot/Mesh Size: _____ Length: _____ Ft. _____				
Hardness		5		Gravel Pack Type: <u>none</u> Volume Used: _____ Depth to Top: _____				
TDS		125		Grout Type: <u>none</u> Volume: _____ Depth: From _____ Ft. to _____ Ft. _____				
PH		7.5		Development Method: <u>AIR</u> Duration: <u>1</u> Hour				
				Pumping Level & Yield: _____ Ft. After _____ Hrs. Pumping <u>20</u> gpm				
				Pump Intake Depth: _____ Ft. Horsepower: _____ Well Disinfected Upon Completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				

CONTRACTOR INFORMATION:

E & D WATER WELLS
Registered Business Name
EL Bean 4-23-16
Signature of Authorization Representative Date

REMARKS: See # 161647316
